



Declaration of Conformity

To the following equipment:				
Product Name: Switching Power Supply				
Model Designation: RSP-75-X (3.3,5,7.5,12,13.5,15,24,27,48)				
is herewith confirmed to dwere applied: RoHS Directive (2011 Low Voltage Directive (/65/EU)	set out in the	e Council	Directive, the following standards
EN61558-1:2005+A1/EN61558-2-16:2009+A1		TUV certificate No : R50266978		
EN60950-1:2006+A11+A1+A12+A2		TUV certificate No: R50266803		
Electromagnetic Compatibility Directive (2014/30/EU):				
EMI (Electro-Magnetic Interference) Conducted emission / Radiated emission EN55032:2015 Class B				
Harmonic current	EN61000-3-2:2014			
Voltage flicker	EN61000-3-3:2013			
EMS (Electro-Magnetic Susceptibility)				
EN55024:2010+A1:2015				
ESD air	EN61000-4-2:2009		Level 3	8KV
ESD contact	EN61000-4-2:2009		Level 2	4KV
RF field susceptibility	EN61000-4-3:2006+A1:2008	+A2:2010	Level 2	3V/m
EFT bursts	EN61000-4-4:2012		Level 2	1KV/5KHz
Surge susceptibility	EN61000-4-5:2014		Level 3	1KV/Line-Line
Surge susceptibility	EN61000-4-5:2014		Level 3	2KV/Line-Earth
Conducted susceptibility	EN61000-4-6:2014		Level 2	3V
Magnetic field immunity	EN61000-4-8:2010		Level 2	3A/m
Voltage dip. interruption	EN61000-4-11:2004 >95% dip (0.5 periods 30	0% dip 25 pe	riods >95% interruptions 250 periods

A component power supply with load will be installed into final equipment which consists of an electronically shielded metal enclosure. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again.

The EMC tests mentioned above are performed using a well defined metal plate to simulate said metal enclosure.

For guidance on how to perform these EMC tests, please refer to "EMI testing of component power supplies".(as available on http://www.meanwell.com)".

This Declaration is effective from serial number EB7xxxxxxx

Person responsible for marking this declaration:

MEAN WELL Enterprises Co., Ltd.

(Manufacturer Name)

Note:

No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 248, Taiwan

(Manufacturer Address)

Johnny Huang/Manager, Certification Center:

(Name / Position)

Alex Tsai/Director, Marketing Department:

(Name / Position)

(Signature)

(Signature)

Taiwan Feb. 21st, 2017

(Place) (Date)